



Water Quality Chemistry Services Lead School Testing Report Date: 3/14/19

## San Diego Unified School District Health and Sciences High

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1284556	01/25/19	06:28 AM	SAMPLE 4	3710020-CHB-A	< 5	ug/L
W1284557	01/25/19	06:29 AM	SAMPLE 5	3710020-CHB-B	< 5	ug/L

<u>Source</u>	Source Description
SAMPLE 4	2nd Floor East side of campus outside of room 200B Right Side, Two wall mount Single Bubblers, lower right bubbler
SAMPLE 5	2nd Floor East side of campus outside of room 200B Right Side. Two wall mount Single Bubblers upper left bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L Action Level (AL) = 15 ug/L  $\,$ 

Tom Burger, Associate Chemist





Water Quality Chemistry Services Lead School Testing Report Date: 3/14/19

## San Diego Unified School District Health and Sciences Middle

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1284553	01/25/19	06:24 AM	SAMPLE 1	3710020-CHA-A	< 5	ug/L
W1284554	01/25/19	06:25 AM	SAMPLE 2	3710020-CHA-B	< 5	ug/L
W1284555	01/25/19	06:21 AM	SAMPLE 3	3710020-CHA-C	< 5	ug/L

Source	Source Description
SAMPLE 1	1st Floor East side of campus outside of room 104,Two wall mount Single Bubblers,upper right bubbler
SAMPLE 2	1st Floor East side of campus outside of room 104,Two wall mount Single Bubblers,lower left bubbler
SAMPLE 3	1st Floor West side of campus outside of room 105, Small basin Bubbler, single bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L Action Level (AL) = 15 ug/L  $\,$ 

Tom Burger, Associate Chemist